



280 Newport Rd, Leola, PA 17540  
Main 717.656.9326 ° Fax 717.656.0910  
www.waypointanalytical.com

5/21/2024

Alan Manufacturing & Supply  
Randie Rineer  
1085 Manheim Pike  
Lancaster, PA, 17601

Ref: Analytical Testing  
Lab Report Number: 24-141-0010  
Client Project Description: James Honberger  
Manheim, PA

Dear Randie Rineer:  
Waypoint Analytical Pennsylvania, Inc. received sample(s) on 5/20/2024 for the analyses presented in the following report.

The above referenced project has been analyzed per your instructions. The analyses were performed in accordance with the applicable analytical method.

The analytical data has been validated using standard quality control measures performed as required by the analytical method. Quality Assurance, method validations, instrumentation maintenance and calibration for all parameters (NELAP and non-NELAP) were performed in accordance with guidelines established by the USEPA (including 40 CFR 136 Method Update Rule May 2021) and NELAC unless otherwise indicated. Any parameter for which the laboratory is not officially NELAP accredited is indicated by a '~' symbol. These are not included in the scope because NELAP accreditation is either not available or has not been applied for. Additional certifications may be held/are available for parameters, where NELAP accreditation is not required or applicable. A full list of certifications is available upon request.

Certain parameters (chlorine, pH, dissolved oxygen, sulfite...) are required to be analyzed within 15 minutes of sampling. Usually, but not always, any field parameter analyzed at the laboratory is outside of this holding time. Refer to sample analysis time for confirmation of holding time compliance.

The results are shown on the attached Report of Analysis(s). Results for solid matrices are reported on an as-received basis unless otherwise indicated. This report shall not be reproduced except in full and relates only to the samples included in this report.

Please do not hesitate to contact me or client services if you have any questions or need additional information.

Sincerely,

  
Robin L Finkill  
Laboratory Manager

*Laboratory's liability in any claim relating to analyses performed shall be limited to, at laboratory's option, repeating the analysis in question at laboratory's expense, or the refund of the charges paid for performance of said analysis.*

Alabama #40750	Louisiana #04015	VA NELAP #460181	Texas #T104704180-11-6	Arkansas #88-0650
Mississippi	California #2904	NC #415	Oklahoma #9311	Virginia #00106
Kentucky #90047	Tennessee #TN02027	EPA #TN00012	Kentucky UST #41	PA NELAP #36-05968



280 Newport Rd, Leola, PA 17540  
 Main 717.656.9326 ° Fax 717.656.0910  
 www.waypointanalytical.com

16800  
 Alan Manufacturing & Supply  
 Randie Rineer  
 1085 Manheim Pike  
 Lancaster , PA 17601

Project James Honberger  
 Information : Manheim, PA

Report Date : 05/21/2024  
 Received : 05/20/2024

Robin L Finkill  
 Laboratory Manager

Report Number : **24-141-0010**

**REPORT OF ANALYSIS**

Lab No : **99454**  
 Sample ID : **Sink Faucet - Honberger**

Matrix: **Aqueous**  
 Sampled: **5/20/2024 9:50**

Test	Results	Units	ML	DF	Date / Time Analyzed	By	Analytical Method
Total Coliform	<1	MPN/100mL	1	1	05/20/24 13:18	RLF	9223B-2004
E-coli	<1	MPN/100mL	1	1	05/20/24 13:18	RLF	9223B-2004

**Qualifiers/ Definitions**      DF      Dilution Factor      ML      Method Quantitation Limit

### Shipment Receipt Form

Customer Number: **16800**  
 Customer Name: **Alan Manufacturing & Supply**  
 Report Number: **24-141-0010**

#### Shipping Method

Fed Ex       US Postal       Lab       Other : \_\_\_\_\_  
 UPS       Client       Courier      Thermometer ID: 1

Shipping container/cooler uncompromised?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
Number of coolers/boxes received	<u>1</u>		
Custody seals intact on shipping container/cooler?	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> Not Present
Custody seals intact on sample bottles?	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> Not Present
Chain of Custody (COC) present?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
COC agrees with sample label(s)?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
COC properly completed	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
Samples in proper containers?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
Sample containers intact?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
Sufficient sample volume for indicated test(s)?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
All samples received within holding time?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
Cooler temperature in compliance?	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
Cooler/Samples arrived at the laboratory on ice. Samples were considered acceptable as cooling process had begun.	<input checked="" type="radio"/> Yes	<input type="radio"/> No	
Water - Sample containers properly preserved	<input checked="" type="radio"/> Yes	<input type="radio"/> No	<input type="radio"/> N/A
Water - VOA vials free of headspace	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> N/A
Trip Blanks received with VOAs	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> N/A
Soil VOA method 5035 – compliance criteria met	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> N/A
<input type="checkbox"/> High concentration container (48 hr)		<input type="checkbox"/> Low concentration EnCore samplers (48 hr)	
<input type="checkbox"/> High concentration pre-weighed (methanol -14 d)		<input type="checkbox"/> Low conc pre-weighed vials (Sod Bis -14 d)	
Special precautions or instructions included?	<input type="radio"/> Yes	<input checked="" type="radio"/> No	

Comments:

Signature: Brandy Haney      Date & Time: 05/20/2024 12:19:20

